

Golden Elite Group - Golden Elite LVT 5mm WET Sliptest Report

22 Mar 2017

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A


Date Tested:	22 Mar 2017
Test Report Number:	BO220317-3
Client Name & Address:	Golden Elite Group - 4 Parkview Dr Archerfield Qld 4108
Location of Test :	4 Parkview Drive Archerfield
Surface / Product Tested :	Golden Elite LVT 5mm Plank SAMPLES
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	27
Fixed / Unfixed Test :	No - Tested in the Direction of least Anticipated Slip Resistance
Testing Officer :	Blair Ording - Munro Portable Skid Tester #0604 - 19.01.16

Testing Officer Signature



Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited.

Test Results :

	Grade Degrees	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	Image of Surface
Plank #1 - Left	< 1.5	50	50	50	50	50	50	
Plank #1 - Centre	< 1.5	50	50	50	50	50	50	
Plank #1 - Right	< 1.5	46	45	45	45	45	45	
Plank #2 - Diagonal	< 1.5	45	45	45	45	45	45	
Plank #2 - Centre	< 1.5	45	45	45	45	45	45	

Mean BPN Slip Resistance Value (SRV)

47

Using Slider 96 (4S) you have achieved a BPN of

P4 = 45 - 54