



New Peal Ceramics - 60x60 GF-L88014 - Wet Sliptest SN220420-2

22 Apr 2020

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	22 Apr 2020
Test Report Number:	SN220420-2
Client Name & Address:	New Pearl Ceramics Group Australia - 2/231 Holt Street PINKENBA QLD 4008
Test Site / Surface Tested :	60x60 GF - L88014
Sample Information :	Samples and Test Information Supplied by Client
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	25
Testing Officer :	Shenea Neill
Testing Officer :	#1133 - 31.10.2019 - Munro-Stanley Portable Skid Tester
Testing Officer Signatory:	

Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	Surface Picture
T1	20	20	19	18	18	18	
T2	20	19	18	18	18	18	
T3	20	20	18	18	18	18	

Variation to Standard Mean BPN Slip Resistance Value (SRV)	18
CLASSIFICATION using Slider 96 (4S Slider)	P1 = 12 - 24

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

