



**New Pearl Ceramics Group Australia - SF-CI1U6003 TILE - Wet Sliptest Report  
KO111018-8**

11 Oct 2018

**Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A**

Date Tested:	11 Oct 2018
Test Report Number:	KO111018-8
Client Name & Address:	New Pearl Ceramics Group Australia - 2/231 Holt Street PINKENBA QLD 4008
Test Site / Project :	PINKENBA DEPOT
Product / Sample Tested :	SF-CI1U6003 TILE
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	25
Testing Officer :	Kathryn Ording - Munro-Stanley Portable Skid Tester #1133 - 30.08.17
Testing Officer Signature	

**Test Results :**

No. of Samples	Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	Surface Picture
1	1A	46	46	46	46	46	46	
	1B	46	46	46	46	46	46	
	1C	50	50	48	48	48	48	

Mean BPN Slip Resistance Value (SRV)

28

Corrected Mean BPN (SRV) Slider 55 ONLY

47

CLASSIFICATION using Slider 96 (4S Slider)

P4 = 45 - 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.